

CLEAR CREEK COUNTY Public and Environmental Health	Systems Cleaners	Section 9
---	-------------------------	----------------------

1. General Requirements for Systems Cleaners

- A. Any person engaged in the cleaning or pumping of septic tanks, vaults, holding tanks, or other components of an OWTS or transporting sewage to a disposal site shall hold a valid Systems Cleaner License from the Department. Employees of a licensed Systems Cleaner need not be individually licensed but the licensed Systems Cleaner shall be onsite, supervising unlicensed employees.

- B. An applicant for a Systems Cleaner License shall pass a test that demonstrates knowledge of these Regulations. The license shall be valid only as long as the person passing the test remains employed by the Systems Cleaner. Full fees pursuant to Section 3.12 shall accompany all Systems Cleaner License applications.

- C. The license period will be valid for one (1) year from the date of issuance. A license that lapses because of failure to renew or is revoked will be subject to the fee established for a new license upon re-application. If the date of re-application is more than one (1) year after the date the license expired, the applicant shall also be required to comply with Section 9.1.B.

- D. Systems Cleaners shall, at a minimum:
 - 1. Remove the liquid, sludge, and scum from all compartments of the tank, leaving no more than a three (3) inches of sewage sludge in the bottom of the tank;

 - 2. Inspect the tees, baffles, aerator unit, pumps, alarms, filters, siphons, and other internal or external components of the tank(s) being pumped and notify the property owner if any of these components are damaged or missing;

 - 3. Inspect and clean any filters or other device which require routine maintenance and cleaning, if necessary;

 - 4. Maintain their equipment so that no spills occur during pumping or transportation and that their employees are not subjected to health hazards from exposure to the sewage;

 - 5. Dispose of the collected sewage only at sites approved by the health officer, such as a permitted wastewater treatment plants; and

 - 6. Maintain records of the activities completed as required in this section, including the volume of septage pumped, date and address for each septic tank pumped, and the date and disposal site for all collected sewage. The health officer may require a Systems Cleaner to provide documentation regarding their disposal methods and practices.

Section 9 System Cleaners

7. Prior to pumping any tank or any other component the Systems Cleaner shall observe to see if the liquid level within the tank is either above or below the inlet or outlet inverts and note this condition on their inspection report as an indication that the STA may either be saturated or the tank may be leaking.
8. Systems Cleaners shall submit all records and reports required under this section to the Department within seven (7) days of cleaning.

E. License Revocation and Suspension

1. The Board of Health may revoke or suspend a Systems Cleaner License for failure to comply with these Regulations.
2. Revocation or suspension will take place only after a hearing before the Board of Health. The licensed Systems Cleaner shall be given no less than ten (10) days' written notice of the hearing sent by personal service or registered or certified mail, return receipt requested. The written notice shall specify the violations which are pertinent to the hearing. A licensed Systems Cleaner shall stop work until the Board of Health reaches decision after the hearing.
3. The licensed Systems Cleaner will be given written notice of the decision and findings of the Board of Health. If the Board of Health finds violations, the written notice of decision will specify the violations to the licensed Systems Cleaner. Such notices will be given to the licensed Systems Cleaner by personal service or registered or certified mail, return receipt requested.
4. A suspended license will be reinstated after completion of the suspension period that was determined by the Board of Health, not to exceed six (6) months, at which time the licensed Systems Cleaner will be given written notice of the reinstatement of their license. Such notices will be given to the licensed Systems Cleaner by personal service or registered or certified mail, return receipt requested. Such suspension period shall not exceed six months. The license shall still expire at the end of the one (1) year period stated on the license.
5. A Systems Cleaner License may reapply for a new license after revocation only after the Systems Cleaner has demonstrated to the health officer the conditions that caused the revocation have been corrected or rectified.